



C A No. Applied For
Complaint No. 16/2026

In the matter of:

Haider

.....Complainant

VERSUS

BSES Yamuna Power Limited

.....Respondent

Quorum:

1. Mr. Shalabh Kumar, Chairman
2. Mr. P.K. Agrawal, Member (Legal)
3. Mr. S.R. Khan, Member (Technical)

Appearance:

1. Mr. Neeraj Sharma, A.R for the complainant
2. Mr. R.S. Bisht, Ms. Monika Sharma, Ms. Chhavi Rani & Mr. Akshat Aggarwal; On behalf of BYPL

ORDER

Date of Hearing: 08th September, 2026

Date of Order: 09th September, 2026

Order Pronounced By:- Mr. P. K. Agrawal, Member (Legal)

1. The brief facts of the grievance are that the complainant has applied for new electricity connection vide request no. 8007987608 at premises no. A-874/20, Shri Ram Colony, Village Khajuri Khas, Delhi-110094, but application of the complainant for new electricity connection was rejected by OP on grounds of "The applied premises fall under HT Line, HT Line 220 KV near the premises and same site dues exist vide CA No. 101542932".

The complainant also stated that the HT line is a bit on a distance from his premises.

Attested True Copy

Secretary
CGRF (BYPL)

Complaint No. 16/2026

2. The respondent in its reply against the complaint of the complainant submitted that the complainant is seeking new electricity connection vide Application No. 8007987608 in his own name for Fourth Floor and Application No. 8007985830 in the name of Naved for Third Floor at premises bearing no. A-874/20, Shri Ram Colony, Village Khajuri Khas, Delhi-110094.

It is further submitted that the premises was inspected by the respondent on 12.11.2026 and thereafter revisited on 02.01.2026. That the inspection revealed that the building structure is Ground + Four Floors. One electricity connection already exist at the applied premises bearing CA No. 154414598 in the name of Gulafsha w/o Zuber Khan. Further a disconnected connection in the name of Krishna Devi bearing CA No. 101542932 exists at the same premises with outstanding dues of Rs. 4,012/-. It is further stated that a 220 KV High Tension overhead transmission line is passing in close proximity to the said building and the horizontal distance between the nearest conductor and the building was approximately 3.50 meters. That the 220 KV line in question is owned, operated and maintained by Delhi Transco Limited (DTL), which is the State Transmission Utility. That without impleadment of DTL, no effective or executable order can be passed, therefore, it is respectfully submitted that DTL is a necessary and proper party to the present proceedings.

3. The complainant in its rejoinder stated that there already a meter exists in the premises and there is a sufficient distance between the HT/LT line and the applied building. It is further requested that proper site visit should be done to grant the electricity connection.

4. Arguments of both the parties are heard.

Attested True Copy

Secretary
CGRI (BYPL)

2 of 3

Complaint No. 16/2026


5. From the perusal of the facts and materials stated before us, we find that the complainant applied for new electricity connection vide request No. 8007987608, at premises bearing no. A-874/20, Shri Ram Colony, Village Khajuri Khas, Delhi-110094, which was rejected by O.P on the grounds of that the property fall under HT line and dues exist on the premises. During the course of the arguments, both the parties conducted joint site visit in which it was cleared that the horizontal distance between the HT line of 220 KV and the applied building is 3.60 meters and the A.R for the complainant agreed to the same.
6. Upon consideration of the material placed on records, this Forum finds that the premises in question are admittedly situated within unsafe horizontal clearance of a 220 KV transmission line and energization of connection would be unsafe in such conditions.

ORDER


The complaint is dismissed. OP has rightly rejected the application of the complainant for new electricity connection.

If the Order is not appealed against within the stipulated time, the same shall be deemed to have attained finally.

Any contravention of these Orders is punishable under Section 142 of the Electricity Act 2003.


(P.K. AGRAWAL)
MEMBER (LEGAL)


(S.R. KHAN)
MEMBER (TECH.)


(SHALABH KUMAR)
CHAIRMAN

3 of 3

Attested True Copy


Secretary
CGRF(BYPL)